

Test Report No. 7191083798-MEC14/1-LAS
dated 28 MAR 2014



PSB Singapore

Choose certainty.
Add value.

Note: This report is issued subject to TÜV SÜD PSB's "Terms and Conditions Governing Technical Services".
The terms and conditions governing the issue of this report are set out as attached within this report.

SUBJECT:

Testing of Plastic Aluminium Composite Panel / Sheet.

TESTED FOR:

Aludecor Lamination Private Limited
1 R.N. Mukherjee Road
5th Floor, Suite No. :
Kolkata 700001
India

Attn: Mr Prashant Ojha

SAMPLES DESCRIPTION:

The following Plastic Aluminium Composite panel / Sheet sample labelled as below were submitted by Aludecor Lamination Private Limited on 18 March 2014 for testing.

Sample Label	Description	Quantity
AL 45 Fire Retardant PE Core	Plastic Aluminium Composite panel / Sheet	10 pcs



Photograph of the samples submitted

TEST METHODS:

ASTM D1781 : 1998 Standard Test Method For Climbing Drum Peel For Adhesives

Test specimen dimension : Drum peel strength test piece
Crosshead speed : 25 mm/min
No. of determinations : 6



Laboratory:
TÜV SÜD PSB Pte. Ltd.
Testing Services
No.1 Science Park Drive
Singapore 118221


Phone : +65-6885 1333
Fax : +65-6776 8670
E-mail: testing@tuv-sud-psb.sg
www.tuv-sud-psb.sg
Co. Reg : 199002667R

Regional Head Office:
TÜV SÜD Asia Pacific Pte. Ltd.
3 Science Park Drive, #04-01/05
The Franklin, Singapore 118223
TUV®



TEST RESULT:

Characteristics	Unit	Plastic Aluminium Composite Panel / Sheet (AL 45 Fire Retardant PE Core)
Drum Peel Torque, average	N.mm/mm	250



Leong A. S.
Higher Associate Engineer

Oh Heng Hwa
Engineer
Polymer Products
Mechanical Centre

Test Report No. 7191083798-MEC14/1-LAS
dated 28 MAR 2014



PSB Singapore

Please note that this Report is issued under the following terms :

1. This report applies to the sample of the specific product/equipment given at the time of its testing/calibration. The results are not used to indicate or imply that they are applicable to other similar items. In addition, such results must not be used to indicate or imply that TÜV SÜD PSB approves, recommends or endorses the manufacturer, supplier or user of such product/equipment, or that TÜV SÜD PSB in any way "guarantees" the later performance of the product/equipment. Unless otherwise stated in this report, no tests were conducted to determine long term effects of using the specific product/equipment.
2. The sample/s mentioned in this report is/are submitted/supplied/manufactured by the Client. TÜV SÜD PSB therefore assumes no responsibility for the accuracy of information on the brand name, model number, origin of manufacture, consignment or any information supplied.
3. Nothing in this report shall be interpreted to mean that TÜV SÜD PSB has verified or ascertained any endorsement or marks from any other testing authority or bodies that may be found on that sample.
4. This report shall not be reproduced wholly or in parts and no reference shall be made by the Client to TÜV SÜD PSB or to the report or results furnished by TÜV SÜD PSB in any advertisements or sales promotion.
5. Unless otherwise stated, the tests were carried out in TÜV SÜD PSB Pte Ltd, No.1 Science Park Drive Singapore 118221.

July 2011

